

PET PORPOISE POOL

65 ORLANDO STREET
COFFS HARBOUR NSW 2450

BATCH NUMBER: 12/0825
No. of SAMPLES: 1
DATE COLLECTED: 10/04/12
DATE RECEIVED: 10/04/12
TIME RECEIVED: 10:20
DATE TESTING COMMENCED:
10/04/12

REPORT OF ANALYSIS

SAMPLE REFERENCE	SAMPLE DESCRIPTION
12/0825/1	Discharge Point # 1

ANALYSIS	METHOD NO	UNITS	12/0825/1
pH	APHA 4500-H+ B	pH unit	8.1
Biochem Oxygen Demand (BOD5)	APHA 5210 B	mg/L	<2
Chlorine Total	EL11B	mg/L	0.43
Total Suspended Solids	APHA 2540 D	mg/L	3
Total Nitrogen	EL30F	mg/L	1.06
Total Phosphorus	EL18F	mg/L	0.12
Faecal Coliforms	APHA 9222 D	cfu/100mL	4

Comments

Sample(s) collected by client and analysed as received in accordance with "Standard Methods for the Examination of Water & Wastewater", 21st Edition, 2005, APHA. Raw data sheets stating analysis dates are available upon request.

Approved:

B J Wadleigh
B J Wadleigh
Laboratory Manager

20/04/12



This document is issued in accordance with NATA's accreditation requirements.

Accredited for compliance with ISO/IEC 17025.
[Accreditation Numbers: 12359 (Chemical) & 14565 (Microbiological)]

The results of the tests, calibrations and/or measurements included in this document are traceable to Australian/national standards.