

PET PORPOISE POOL
 SPENCER PICKERING
 65 ORLANDO STREET
 COFFS HARBOUR NSW 2450

BATCH NUMBER: 12/2095
 No. of SAMPLES: 1
 DATE COLLECTED: 25/09/12
 DATE RECEIVED: 25/09/12
 TIME RECEIVED: 15:00
 DATE TESTING COMMENCED:
 25/09/12


REPORT OF ANALYSIS

SAMPLE REFERENCE	SAMPLE DESCRIPTION
12/2095/1	Discharge Point # 1

ANALYSIS	METHOD NO	UNITS	12/2095/1
pH	APHA 4500-H+ B	pH unit	8.0
Biochem Oxygen Demand (BOD5)	APHA 5210 B	mg/L	<2
Chlorine Total	EL11B	mg/L	0.02
Total Suspended Solids	APHA 2540 D	mg/L	12
Total Nitrogen	EL30F	mg/L	1.29
Total Phosphorus	EL18F	mg/L	0.24
Faecal Coliforms	APHA 9222 D	cfu/100mL	0

Comments

Sample(s) collected by client and analysed as received in accordance with "Standard Methods for the Examination of Water & Wastewater", 21st Edition, 2005, APHA. Raw data sheets stating analysis dates are available upon request.

Approved: 
 B J Wadleigh
 Laboratory Manager

5/10/12



This document is issued in accordance with NATA's accreditation requirements.

Accredited for compliance with ISO/IEC 17025.
 [Accreditation Numbers: 12359 (Chemical) & 14565 (Microbiological)]

The results of the tests, calibrations and/or measurements included in this document are traceable to Australian/national standards.