

DOLPHIN MARINE MAGIC
KIERAN MARSHALL
65 ORLANDO STREET
COFFS HARBOUR NSW 2450

BATCHNUMBER: 17/0500
No. of SAMPLES: 1
DATE COLLECTED: 06/03/17
DATE RECEIVED: 06/03/17
TIME RECEIVED: 10:40
DATE TESTING COMMENCED:
06/03/17

REPORT OF ANALYSIS

SAMPLE REFERENCE	SAMPLE DESCRIPTION
17/0500/1	Discharge Point # 1

ANALYSIS	UNITS	17/0500/1				METHOD NO
pH	pH unit	8.1				APHA 4500-H+ B
Biochem Oxygen Demand (BOD5)	mg/L	<2				APHA 5210 B
Chlorine Total	mg/L	0.37				EL11B
Total Suspended Solids	mg/L	11				APHA 2540 D
Total Nitrogen	mg/L	<0.5				EL30F
Total Phosphorus	mg/L	0.69				EL18F
Faecal Coliforms	cfu/100mL	0				ELM 3

Comments

Sample(s) collected by client and analysed as received in accordance with "Standard Methods for the Examination of Water & Wastewater", 22nd Edition, 2012, APHA. Raw data sheets stating analysis dates are available upon request.

Tests marked with '#' are not covered by NATA Accreditation.

Note: Microbiological results are membrane presumptive.


Nutrient analysis conducted by a subcontracted laboratory (NATA Accreditation Number 825) RN: ES1705617.

Report Date: 21/03/17



Accredited for compliance with ISO/IEC 17025.
[Accreditation Numbers: 12359 (Chemical) & 14565 (Microbiological)]

Approved:


B J Wadleigh
Laboratory Manager