

DOLPHIN MARINE MAGIC  
KIERAN MARSHALL  
65 ORLANDO STREET  
COFFS HARBOUR NSW 2450

BATCHNUMBER: 17/1138  
No. of SAMPLES: 1  
DATE COLLECTED: 05/06/17  
DATE RECEIVED: 05/06/17  
TIME RECEIVED: 10:02  
DATE TESTING COMMENCED:  
05/06/17

### REPORT OF ANALYSIS

SAMPLE REFERENCE	SAMPLE DESCRIPTION
17/1138/1	Discharge Point # 1

ANALYSIS	UNITS	17/1138/1				METHOD NO
pH	pH unit	8.0				APHA 4500-H+ B
Biochem Oxygen Demand (BOD5)	mg/L	<2				APHA 5210 B
Chlorine Total	mg/L	0.36				EL11B
Total Suspended Solids	mg/L	23				APHA 2540 D
Total Nitrogen	mg/L	0.59				EL30F
Total Phosphorus	mg/L	0.62				EL18F
Faecal Coliforms	cfu/100mL	0				ELM 3

#### Comments

Sample(s) collected by client and analysed as received in accordance with "Standard Methods for the Examination of Water & Wastewater", 22nd Edition, 2012, APHA. Raw data sheets stating analysis dates are available upon request.

Tests marked with '#' are not covered by NATA Accreditation.


Note: Microbiological results are membrane presumptive.

Report Date: 13/06/17



Accredited for compliance with ISO/IEC 17025.  
[Accreditation Numbers: 12359 (Chemical) & 14565 (Microbiological)]

Approved:

  
B J Wadleigh  
Laboratory Manager