

COFFS HARBOUR LABORATORY

Environmental Analysis

Page 1 of 1



DOLPHINMARINEMAGIC
KIERANMARSHALL
65 ORLANDOSTREET
COFFS HARBOUR NSW 2450

BATCHNUMBER: 20/2289
No. of SAMPLES: 1
DATE COLLECTED: 06/10/20
DATE RECEIVED: 06/10/20
TIME RECEIVED: 13:20
DATE TESTING COMMENCED:
06/10/20

REPORT OF ANALYSIS

SAMPLE REFERENCE	SAMPLE DESCRIPTION
20/2289/1	Discharge Point # 1

ANALYSIS	UNITS	20/2289/1			METHOD NO
pH	pH unit	8.4			APHA 4500-H+ B
Biochem Oxygen Demand (BOD5)	mg/L	<2			APHA 5210 B
Chlorine Total	mg/L	0.15			EL11B
Total Suspended Solids	mg/L	5			APHA 2540 D
Total Nitrogen	mg/L	0.50			EL30F
Total Phosphorus	mg/L	0.56			EL18F
Faecal Coliforms	cfu/100mL	0			ELM 3

Comments

Sample(s) collected by client and analysed as received in accordance with "Standard Methods for the Examination of Water & Wastewater", 23rd Edition, 2017, APHA. Raw data sheets stating analysis dates are available upon request.

Tests marked with '#' are not covered by NATA Accreditation.

Note: Microbiological results are membrane presumptive.

Measurement Uncertainty is available upon request.

Report Date: 13/10/20



Accredited for compliance with ISO/IEC 17025 - Testing
[Accreditation Numbers: 12359 (Chemical) & 14565 (Microbiological)]

Approved:

Shane Ewart - Delegate for

B J Wadleigh
Laboratory Manager

The results of the tests, calibrations and/or measurements included in this document are traceable to Australia